



101 Lucas Valley Road, Suite 300
 San Rafael, CA 94903
 Tel.: 415-472-1734
 Fax: 415-499-7715
 www.LGVSD.org

MANAGEMENT TEAM
 General Manager, Curtis Paxton
 Plant Operations, Mel Liebmann
 Collections/Safety/Maintenance, Greg Pease
 Engineering, Michael P. Cortez
 Administrative Services, Dale McDonald

DISTRICT BOARD
 Megan Clark
 Craig K. Murray
 Barry Nitzberg
 Gary E. Robards
 Crystal J. Yezman

ADDENDUM NO. 3

Date: August 8, 2024
 Project: **Smith Ranch Pump Station Improvements**
 Job No.: 20300-09

To: All Plan holders and Prospective Bidders

The following changes and/or clarifications are hereby made to the Contract Documents and shall become a part of the Contract Documents dated June 2024.

Questions Received from Proposers/Bidders:

The following questions were submitted on or before 8/7/2024, questions that are received after the bid questions deadline may not be answered in an addendum. LGVSD responses to the questions are in bold.

- 1) Additional question/comment regarding a design inconsistency with this project; the General Electrical Provisions, Spec 16010 under 1.04 System Description, E. Natural Gas for Standby Generator calls for replacement of the gas meter for the new standby generator which is specified now to be diesel fired. Please confirm that the existing gas meter currently used for the generator can remain in place and only the gas line needs to be removed along with the existing natural gas fired standby generator.

Given this inconsistency, Telstar plans to quote including only the removal of the gas line feeding the generator and removal of the generator.

Response: General sections of the Contract specifications are broader and encompass a wider range of possible construction than the actual scope directed by the drawings. The existing gas meter shall remain intact and the existing gas line to the existing generator shall be removed per Detail 5/E009 and E009, Note 1.

This addendum consists of one (1) page including this page and attachments. Acknowledge receipt of this addendum in the space provided on page 95 of 528, Proposal Cover Page and Bid Schedule, of the Bid Forms, and by signing in the space provided below. Submit an original copy of this addendum cover page along with the bid. Failure to do so may disqualify the bidder.

Las Gallinas Valley Sanitary District: Bidder: _____

Michael P. Cortez, PE, District Engineer (Authorized Signature) _____ (Date)