



101 Lucas Valley Road, Suite 300
 San Rafael, CA 94903
 Tel.: 415-472-1734
 Fax: 415-499-7715
 www.LGVSD.org

MANAGEMENT TEAM
 General Manager, Curtis Paxton
 Plant Operations, Mel Liebmann
 Collections/Safety/Maintenance, Greg Pease
 Engineering, Michael P. Cortez
 Administrative Services, Dale McDonald

DISTRICT BOARD
 Megan Clark
 Craig K. Murray
 Barry Nitzberg
 Gary E. Robards
 Crystal J. Yezman

ADDENDUM NO. 2

Date: August 20, 2024
 Project: **Sewer Main Rehabilitation 2024 (with Inflow & Infiltration Reduction)**
 Job No.: 24460-06 & 24460-07

To: All Planholders and Prospective Bidders

The following changes and/or clarifications are hereby made to the Contract Documents and shall become a part of the Contract Documents dated July 2024.

1. Manhole Liner System: There exists a discrepancy between the technical specifications and drawings regarding manhole liner. Volume 4 Drawings, Sheet SD5, Manhole Liner Performance Criteria Note No. 4 shall govern.

4. MANHOLE LINER SYSTEM SHALL BE:

A. MAINSTAY ML-72 SPRAYABLE MICROSILICA CEMENT MORTAR; MAINSTAY DS-5 ULTRA HIGH BUILD EPOXY COATING; MADEWELL 806 FLEXIBLE JOINT SEALANT; MAINSTAY ML-10 HYDRAULIC CEMENT MORTAR AS MANUFACTURED BY MADEWELL PRODUCTS CORPORATION, ALPHARETTA, GEORGIA, (800) 741-8199, FAX (770) 475-8167. INSTALL PER MANUFACTURER'S RECOMMENDATION.

B. OR APPROVED EQUAL.

Questions Received from Proposers/Bidders:

The following questions were submitted on or before 8/20/2024, questions that are received after the bid question deadline may not be answered in addendum. LGVSD responses to the questions are in bold.

- Q1. Note 2 on Sheet SD5 states that the Manhole Liner System shall be Mainstay ML-72 sprayable microsilica cement coating. Specification 09 93 00-1.01C.3 states that the liner shall be Multiplex Liner System Type PVC/P by Terre Hill composites which is a cured in place liner. Please confirm as to which type of lining is required.

Response: See Item No. 1 above.

This addendum consists of one (1) page including this page and attachments. Acknowledge receipt of this addendum in the space provided on page 95 of 452, Proposal Cover Page and Bid Schedule, of the Bid Forms, and by signing in the space provided below. Submit an original copy of this addendum cover page along with the bid. Failure to do so may disqualify the bidder.

Las Gallinas Valley Sanitary District: Bidder: _____

Michael P. Cortez, PE, District Engineer

(Authorized Signature)

(Date)